



10006/2/1

Diagnostic and battery module (DBM)

Description

The diagnostic and battery module (DBM) 10006/2/1 provides a low-cost interface to the user for diagnosing the FSC system. The displays on the front of the module are used to display messages about the faults found by the diagnostic routines. The message gives type, rack and position number of the module found to be faulty.

In addition to the diagnostic messages, the DBM module is provided with a real-time clock function which gives the current date and time. Both date and time can be displayed on the front of the DBM module and can be read by the application program.

The DBM module is able to display the temperature values measured by two independent temperature sensors inside the Central Part of the FSC system, as well as the 5 Vdc level and the battery voltage. High and low alarm points and high and low trip points can be entered for the temperature measurement during DBM configuration in the 'Configure FSC system' program.

The switch at the front of the DBM module can be operated to retrieve system information (switch upwards) or diagnostic information (switch downwards).

To get all information, the switch must be operated several times.




Figure 1
Front view

The diagnostic information is displayed as follows:

Top display:	Signal type:
<i>A</i> <i>I</i>	Analog input fault
<i>d</i> <i>I</i>	Digital input fault
<i>A</i> <i>o</i>	Analog output fault
<i>d</i> <i>o</i>	Digital output fault
<i>C</i> <i>P</i>	Central part fault
<i>E</i> <i>L</i>	Temperature low
<i>E</i> <i>H</i>	Temperature high
<i>c</i> <i>E</i>	HBD correlation (address HBD not set correct)
<i>h</i> <i>b</i>	HBD fault

Middle display: Rack number
Bottom display: Position number

The display will normally show the time (hours, minutes, seconds) and will automatically return to this mode when the switch is not used for approx. 30 seconds.



A flashing display indicates that a system fault is present and diagnostic information may be available.

A blank display means that no diagnostic information is present or diagnostic information was read before.

The system information cycle has four stages which can be called up by (repeatedly) moving the switch upward (see Table 1).

Table 1 Switch operation for system information

Switch moved upward →	0x	1x	2x	3x	4x
Top display	Day			5 Vdc units	Battery units
Middle display	Date	Degree 1	Degree 2	5 Vdc decimals	Battery decimals
Bottom display	Month	Unit	Unit		

Diagnostic messages, if they are available, can be retrieved by (repeatedly) moving the switch downward:

Temperature alarm

T. Temperature
Pr. Pre
AL. Alarm

Second fault timer started

F.T. Fault timer
AL. Alarm

External communication error

E. External
Co. Communication
AL. Alarm

Internal communication error

I. Internal
Co. Communication
AL. Alarm

Transmitter fault alarm

AI. Analog input
Tr. Transmitter
AL. Alarm

Redundant input fault alarm

rd. Redundant
I. Input
AL. Alarm

Device communication error

d. Device
Co. Communication
AL. Alarm

Module faulty (example)

do Digital output fault
03 Rack 3
15 Position 15



Batteries

The DBM module holds the rechargeable batteries that supply the back-up power for the RAM memory on the CPU (10002/1/1 or 10002/1/2), COM modules (10004/./.) and MEM modules (10003/1/1).

It is recommended that the batteries are replaced every four years.

Jumpers

Jumper J1 switches the batteries in stock (OFF) or in circuit (ON). Jumpers J2 and J3 are factory-set (closed).




Figure 2 Jumper settings on 10006/2/1 module



Technical data

The 10006/2/1 module has the following specifications:

General	Type number:	10006/2/1 08801*
	Approvals:	CE, TÜV, UL
	Software versions:	≥ 2.90
	Space requirements:	8 TE, 3 HE (= 8 HP, 3U)
	Time drift:	< 1 sec/day
Power	Power requirements:	5 Vdc 300 mA
	Ripple content:	< 50 mV p-p
Batteries	Back-up capacity:	0.5 Ah

Note:

* 10006/2/1 modules with suffix code 08801 have an improved noise immunity.

Note:

Do not remove or replace this module while the power to its Central Part is on.

While this information is presented in good faith and believed to be accurate, Honeywell Safety Management Systems B.V. disclaims the implied warranties of merchantability and fitness for a particular purpose and makes no express warranties except as may be stated in its written agreement with and for its customer. In no event is Honeywell Safety Management Systems B.V. liable to anyone for any indirect, special or consequential damages. The information and specifications in this document are subject to change without notice.